

NEBRASKA

Downloaded January 2011

12-007.03E Dining Areas: Dining areas must have an outside wall with windows for natural light and ventilation. Dining areas must:

1. Be furnished with tables and chairs that accommodate or conform to resident needs;
2. Have a floor area of 15 square feet per resident in existing facilities and 20 square feet per resident in new construction;
3. Allow for group dining at the same time in either separate dining areas or a single dining area, dining in two shifts, or dining during open dining hours; and
4. Not be used for sleeping, offices, or corridors.

12-007.04E Electrical System: The facility must have an electrical system that has sufficient capacity to maintain care and treatment services provided. The electrical system must be properly grounded.

12-007.04E2 The facility must provide minimum illumination levels as follows:

3. Personal care and dining areas: 20 foot candles;