

## **SECTION 2200 - HAZARDOUS ELEMENTS OF CONSTRUCTION**

### **2201. Hazardous Elements (II)**

Construction and installation of the following components shall conform to the requirements of the applicable sections of the adopted State, Federal, or local codes, ordinances, and regulations, whichever is most stringent:

A. Furnaces and Boilers.

B. Dampers.

C. Incinerators.

1. Incinerators when used shall conform to the requirements of R.61-79.

2. Incinerators located within the facility shall be separated from the rest of the building by walls, partitions, floor and ceiling construction having a fire resistant rating of not less than two (2) hours.

3. Combustion air shall be discharged to the outside and ventilation air shall be taken from the outside.